

# Scaffold Hazard Checklist

Site Address: \_\_\_\_\_

<b>Hazard Mitigation</b>		<b>Satisfactory</b>	<b>Needs Attention</b>	<b>Not Applicable</b>	<b>Target Date for Completion</b>	<b>Date Completed</b>
1.	The scaffold was erected under the supervision and direction of a <b>qualified person</b> .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
2.	A permit was obtained if the scaffold is over <b>36 feet</b> .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
3.	The scaffold erectors have been properly trained.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
4.	The <b>scaffolding components</b> and planking are safe to use.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
5.	Hazardous environmental conditions have been prepared for (e.g. high winds, lightning, snow, ice, and/or rain).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
6.	Only <b>scaffold grade planking</b> is used.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
7.	The scaffold is capable of safely carrying the <b>intended load</b> .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
8.	<b>Screw jacks</b> used to level and plumb the scaffold meet Ca/OSHA requirements.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
9.	Scaffolding platforms <b>are level</b> (the slope should be no more than 2:10).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
10.	The <b>base plates</b> are used on all scaffold legs and are installed correctly.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
11.	The scaffold legs are resting on base plates provided by the manufacturer.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
12.	The base plates are resting on and nailed to 2x10x10 wood bases when on earth or soft material.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
13.	<b>Scaffolding</b> is completely railed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
14.	Top rails of the scaffold are at 42 inches.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
15.	A mid rail or cross bar is in place.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
16.	End rails are in place.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
17.	Proper <b>access</b> is provided to all levels of the scaffolding.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
18.	<b>Ladders</b> used to access the scaffold are in good condition, properly braced, anchored, and extended 36 inches above the platform.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
19.	Braces are installed to reinforce the legs of the scaffold.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
20.	Where necessary, <b>toeboards</b> have been installed properly.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
21.	If the height of the scaffold exceeds 3 times the least base dimension of the frame, <b>ties, stabilizers, and or outriggers</b> are used.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
22.	If ties are used, the scaffold is tied off using 10 gauge (single looped) or 12 gauge (double looped) wire.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

### Actions Taken to Correct Items Checked as “Needs Attention”

Hazard #	

Name

Date

*The above evaluations and/or recommendations are for general guidance only and should not be relied upon for medical advice or legal compliance purposes. They are based solely on the information provided to us and relate only to those conditions specifically discussed. We do not make any warranty, expressed or implied, that your workplace is safe or healthful or that it complies with all laws, regulations or standards.*

For more information, visit: [www.SafeAtWorkCA.com](http://www.SafeAtWorkCA.com)